

DD-34

R No: 955/45

7293



Ahmedabad Municipal Corporation  
HEALTH DEPARTMENT

No. 732

Date: 23/02/2028

## Sanitary Convenience Certificate

A Certificate for Sanitary Convenience is issued to the Manager / Secretary / Organiser  
of the <sup>School</sup> Talkies / Theatre named "ST. KABIR SCHOOL"  
- Smt. Charn Nautiyal Situated  
at Nr. Sureshwar Circle, Thaltej for  
the period of 12 months / Days i. e. from 01/01/2028 to 31/12/2028

"Issued Subject to NOC from other Concerned Departments"

Copy to :-

1. The manager/Secretary of the Theater/Organiser
2. The Commissioner of Police, Ahmedabad.

Sanitary Superintendent  
North West Zone (AMC)

Dy. Director (S.W.M.)  
Dy. Health Officer  
Ahmedabad Municipal Corporation  
North West Zone, A.M.C.

Zone: North West Zone



AHMEDABAD MUNICIPAL CORPORATION  
MAHANAGAR SEVA SADAN  
**CENTRAL LABORATORY**  
(An ISO 9001: 2015 Accredited Laboratory)



Lic No QAC/R91/4650

Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India

E-mail: [centrallab@ahmedabadcity.gov.in](mailto:centrallab@ahmedabadcity.gov.in), Phone No-(079) 25631105, 25630438

May 19, 2026.

To,  
The Principal,  
Sant Kabir School  
Nr.Goyal Intercity, Surdhara Circle  
Drive-in Road, Thaltej, Ahmedabad.

**Dear Sir,**

We have analyzed your water samples collected on Dt. 08-05-2026 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

| Sr. No. | Parameter                                           | Requirement (Acceptable Limit)               | Permissible Limit in the Absence of Alternate Source | Sample Value   |
|---------|-----------------------------------------------------|----------------------------------------------|------------------------------------------------------|----------------|
|         |                                                     | As per IS-10500-2012                         |                                                      |                |
| A.      | Organoleptic and Physical Parameters                |                                              |                                                      |                |
| 1       | Colour, Hazen units, Max                            | 5                                            | 15                                                   | 0.1            |
| 2       | pH value                                            | 6.5-8.5                                      | No relaxation                                        | 7.10           |
| 3       | Turbidity, NTU, Max                                 | 1                                            | 5                                                    | 0.18           |
| 4       | Total dissolved solids, mg/l, Max                   | 500                                          | 2000                                                 | 292            |
| B.      | General Parameters                                  |                                              |                                                      |                |
| 1       | Total hardness (as CaCO <sub>3</sub> ), mg/l, Max   | 200                                          | 600                                                  | 60             |
| 2       | Calcium (as Ca), mg/l, Max                          | 75                                           | 200                                                  | 16             |
| 3       | Magnesium (as Mg), mg/l, Max                        | 30                                           | 100                                                  | 4.88           |
| 4       | Chloride (as Cl), mg/l, Max                         | 250                                          | 1000                                                 | 70             |
| 5       | Sulphate (as SO <sub>4</sub> ) mg/l, Max            | 200                                          | 400                                                  | 18.8           |
| 6       | Total alkalinity (as CaCO <sub>3</sub> ), mg/l, Max | 200                                          | 600                                                  | 130            |
| 7       | Free residual chlorine, mg/l, Min                   | 0.2                                          | 1.0                                                  | Nil            |
| C.      | Bacteriological Quality of Drinking Water           |                                              |                                                      |                |
| 1       | Total Coliform bacteria, MPN/100 ml.                | Shall not be detectable in any 100 ml sample | Shall not be detectable in any 100 ml sample         | Not Detectable |
| 2       | E. coli, MPN/100 ml.                                | Shall not be detectable in any 100 ml sample | Shall not be detectable in any 100 ml sample         | Not Detectable |

**Remarks:**

- The Central Laboratory, AMC, has collected the samples.
- The result contained in this report relate only to the sample material tested.
- The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE – It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated

*[Signature]*  
**Scientist In-Charge**  
**Central Laboratory**

19/5  
56.